

LCCP in Water Facilities

The Pouderoyen Water Rehabilitation Project

Case Hystory

by

CIS ECOLOGIA

THE PROJECT PWRP

- Financing: EU - EDF
- Value: 6.5 m€
- water treatment and distribution: 6.000 cu.m/d
- Population served : 25,000 ab.
- Client : Guyana Water Authority, now (GWI)
- Contractor: CIS ECOLOGIA -Italy
- Preliminary design: Garland Ormond - Ireland
- Supervision: Vikab – Guyana
- Works duration 24 months

Pouderoyen treatment unit



booster pumps




ELF CIS ECOLOGIA

Backwash and air blowers



LCCP Model in the Project Cycle



Strategic Level

- LCC1 (client brief)
- Total cost (EPV) of the utility during its life span:
 - Design,
 - Finance,
 - Build,
 - Operate,
 - Maintain,
 - Environmental asses.....
 - Decommissioning....

Identification of the major class of cost originated by the project and ranking of the same in terms of % of the:
investment cost ;
LLC (PV)

Client Brief – preliminary data input

WWTP - CLIENT BRIEF - DATA LOG

Water Treatment Plant

1



LCC CALC



ENV

click for E module

INPUT				
			MIN.	MAX.
1	expected operating life	years	30	40
2	population served (actual)	n.	20.000	30.000
3	population served (in 10-20 yrs)	n.	30.000	40.000
4	<i>population density</i>	select	low	low
5	<i>industrialisation level</i>	select	low	low
6	<i>morphological context</i>	select	flat	flat
7	<i>row water source</i>	select	underground	underground
8	<i>reticulation needed ?</i>	yes/no	no	no
9	<i>land available ?</i>	yes/no	yes	yes
10	<i>site infrastructure available ?</i>	yes/no	no	no
11	standard water consumption (per capita)	cu.m./ab.d	0,1	0,2

Project: Phase:	Pouderoyen Water Rehabilitation Client Brief Level Concept Design Detailed Design Level	Yes/No Yes/No Yes		Environmental Impact Assessment needed? Directive 11/ 97/ CE click for screening guidance	
Completed by: Date: March 2004	CIS ECOLOGIA srl 10-mar-04			EIA GUIDELINES SCREENING	

Service life (years) 50	Phase	Weights (%)	Environmental impacts	Weights (%)	Parameter	Weights (%)	Yes: 1 Partly: 0.5 No: 0	Points
Period of analysis (years) 50								
Environment	Design / Construction	15	Site	33	view impact mitigation noise / odor mitigation	50 50	0,0 1,0	0,0 2,5
			<i>Sum</i>			100		2,5
			Process / materials	33	Water Treatment process Sludge Treatment process Electro-mechanical Efficiency Env. Declaration or label Gravity flow design	50 0 25 0 25	0,5 0,0 0,5 0,0 1,0	1,3 0,0 0,6 0,0 1,3
			<i>Sum</i>			100		3,1
			Waste	33	Material management Waste reduction	50 50	0,0 0,5	0,0 1,3
			<i>Sum</i>			100		1,3
	<i>Sum Construction</i>			100				6,9
	Operating & Maintenance	80	Energy	25	High efficiency equipment Monitoring and control Solar cells Remote control equipment Service Buildings back wash efficiency	17 17 17 17 17 17	0,5 0,5 0,0 0,5 1,0 0,5	1,7 1,7 0,0 1,7 3,3 1,7
			<i>Sum</i>			100		10,0
			Materials / Consumables	25	Chemicals Dosing Env. Sound maintenance Replacement frequency	33 33 33	0,0 1,0 0,5	0,0 6,7 3,3
			<i>Sum</i>			100		10,0
			Raw Water	25	Raw water control Backwash	50 50	0,0 0,0	0,0 0,0
			<i>Sum</i>			100		0,0
			Treated Water	25	Effluent Water Control Water Storage	50 50	0,5 1,0	5,0 10,0
			<i>Sum</i>			100		15,0
	<i>Sum Operating & Maintenance</i>			100				35,0
	Disposal & Residual Value	5	Disposal	100	Design - sorting and reuse Materials - sorting and reuse Residual value environmentally	33 33 33	0,5 0,5 0,5	0,8 0,8 0,8
			<i>Sum</i>			100		2,5
	<i>Sum Disposal & Residual Value</i>			100				2,5
Scoring Environment		100						44,4

It continues in the next page.

Occupation	Operating & Maintenance (Service Buildings)	100	Air quality and temp.	33	Adjustable temperature	33	0,5	5,6
					Harmful fumes	33	1,0	11,1
					Ventilation	33	0,5	5,6
			<i>Sum</i>			100		22,2
			Daylight and lighting	33	Daylight	50	1,0	16,7
					Sunlight protection	50	0,5	8,3
			<i>Sum</i>			100		25,0
			Indoor noise	33	Design	50	0,0	0,0
					Materials and components	50	0,0	0,0
			<i>Sum</i>			100		0,0
	<i>Sum Occupation</i>			100				47,2
Scoring Occupation		100						47,2
Mobility	Operating & Maintenance	100	Transport	100	Public transport	20	0,5	10,0
					Usage of public tr.; staff	20	0,5	10,0
					Transport distance; staff	20	0,5	10,0
					Access road	20	1,0	20,0
					Usage of public tr.; customers	20	0,5	10,0
			<i>Sum</i>			100		60,0
	<i>Sum Mobility</i>			100				60,0
Scoring Mobility		100						60,0
Society	Construction and Operating and Maintenance	100	Location	50	Historic sites	0		0,0
					Infrastructure	50	0,5	12,5
					Manpower	50	0,5	12,5
			<i>Sum</i>			100		25,0
			Regional development	50	Impact on surroundings	33	1,0	16,7
					Reliability of supply	33	1,0	16,7
					Urban development	33	1,0	16,7
			<i>Sum</i>			100		50,0
	<i>Sum Society</i>			100				75,0
Scoring Society		100						75,0
Total Assessment						Weights %		
Scoring Environment						30	44	13,3
Scoring Occupation						40	47	18,9
Scoring Mobility						15	60	9,0
Scoring Society						15	75	11,3
			<i>Sum</i>			100		52,5
Total Scoring	Scoring <50=Poor, 50-60=Average, 60-70=Satisfactory, 70-80=Good, 80-90=Very Good, >90=Excellent					AVERAGE		52,5

The score is registered in the logbook?

LIFE CYCLE COST PERFORMANCE MODEL - CLIENT BRIEF STAGE

Project	PWRP					
Study period	32,5	years				
Construction period	2	years				
Nominal discount rate	0,06					Own Distribution
Inflation rate	Min	0,02	Max	0,06		
Real discount rate	0,02					
Consider revenues	y					

LIFE CYCLE COST PERFORMANCE MODEL - CLIENT BRIEF STAGE

					Expected Present Value			
Project Life Cycle Costs					19.652.077			
		No of units	Cost per unit				% of LCC	% of Capital Cost
			Min	Max	Most Likely			
Capital Cost		1	3.600.000	8.000.000	6.000.000	5.866.667	29,85%	
Facility Management Cost						13.550.410	68,95%	230,97%
- Operation (per year)		1	180.000	400.000	230.000	5.955.392	30,30%	101,51%
- Maintenance (per year)		1	90.000	200.000	125.000	3.051.219	15,53%	52,01%
- Capital Replacement						2.816.000	14,33%	48,00%
PV Percentage on capital cost	n							
Annual Percentage on capital cost	y		0,39	0,60	0,45			
- Other FM costs (per year)		1	60.000	100.000	75.000	1.727.799	8,79%	29,45%
Costs at end of study period			-	-	-	-	0,00%	0,00%
Management costs			180.000	300.000	225.000	235.000	1,20%	4,01%
Overhead costs			-	-	-	-	0,00%	0,00%
Project Cash Flow			Min	Max	Most Likely			
Cash flow in present value			7.265.700	12.916.800	10.000.000	10.060.833,33		
Net Present Value						- 9.591.243,58		



LCC1




- The result of the exercise is:
 - The expected present value(LCC),
 - The % of different operations..
- The LCC value has a number of limits related to the evolution of the economic and financial situation...
- It works better if used to compare alternative solutions....
- The ranking in the component of costs is very usefull to identify on which part of the project's operation are the major costs



Client Brief


(@risk output)

Distribution for Project Life Cycle Costs - Present Valu...



Client Brief (@risk output)

Regression Sensitivity for Project Life Cycle Costs - Pr...





LCC1

- What kind of information and expertise do we need to operate at LCC1 level?
 - Terms of reference (Project identification)
 - Standardised costs
 - General Technical knowledge of the process.....
 - » indication about the lifespan
 - » What Environmental general factors should be considered?



- What kind of info do we expect / provide with our database?
- What kind of Env. Consideration could be introduced?
- It is possible, with the level of info available at CB stage, to compare?
 - » The exercise is limited to the main financial indicators and env. considerations

LCC1

- This is an example of comparison of LCC % at different inflation and discount rates....NOT RELATED to the PWRP case history

Project	waste water treatment plant			
Study period	35	years		
Construction period	2	years		
Nominal discount rate	0,04			Own Distribution
Inflation rate	Min	0,025	Max	0,045
Real discount rate	0,00			
Consider revenues	y			

Expected Present Value		
17.918.194		
	% of LCC	% of Capital Cost
2.683.333	14,98%	
14.999.860	83,71%	559,00%

Project	waste water treatment plant			
Study period	35	years		
Construction period	2	years		
Nominal discount rate	0,05			Own Distribution
Inflation rate	Min	0,02	Max	0,035
Real discount rate	0,02			
Consider revenues	y			

Expected Present Value		
14.365.617		
	% of LCC	% of Capital Cost
2.683.333	18,68%	
11.447.283	79,69%	426,61%

LCC2 (concept design)

- Comparative evaluation of EPV with respect to alternative technical, solutions

Identification of most of the components for any class of cost originated by the project and ranking of the same in terms of % of :

investment cost ;

WLC (PV)

LCC2

- What kind of information and expertise do we need to operate at this level?
 - More detailed terms of references, including location, client and user characteristics, etc
 - » We have the general specs of tender docs
 - More technical background and knowledge
 - Cost database linked to the location
 - » Example of cost of manpower

LCC2

- What kind of info do we expect / provide with our database?
 - We propose the costs per class of work
 - It is possible, with the level of info available at Conc.Design stage, to compare? Yes, if...
- what kind of Env. Consideration could be introduced?

LIFE CYCLE COST PERFORMANCE MODEL - CONCEPT DESIGN STAGE

Project	Pouderoyen Water Rehabilitation Project				
Study period	32,5	years			
Construction period	2	years			
Nominal discount rate	0,03				Own distribution
Inflation rate	Min	0,008	Max	0,01	
Real discount rate	2%				
Consider Cash-Flows	y				

LIFE CYCLE COST PERFORMANCE MODEL - CONCEPT DESIGN STAGE

	Cost			Own distribution	Expected Present value
	Min	Max	Most Likely		
Capital Cost					5.013.815,05
Management Costs	340.000	560.000	480000		460.000,00
Overheads	380.608	418.330	400000		399.646,05
Design Costs					131.947,51
Construction					3.958.425,23
<i>Indirect costs/Prelims</i>					359.856,84
- Site Overheads	0,000	0,000	0,000		-
Management	0,040	0,080	0,050		203.918,88
Plant	0,010	0,030	0,020		71.971,37
Other (transport)	0,020	0,030	0,020		83.966,60
	Cost per unit				
<i>Direct costs</i>	Min	Max	Most Likely		3.598.568,39
- Supply of Material and equipments	1.615.021	1.795.446	1.650.000		1.686.822,36
- Substructure (foundations)	383.670	436.872	400.000		406.847,26
- Treatment unit	805.704	1.010.000	950.000		921.901,33
- buildings	230.202	243.400	235.000		236.200,66
- Erection and Assembling	77.469	193.254	100.000		123.574,23
- Services	124.821	156.026	145.000		141.948,76
- External Works	51.156	107.665	85.000		81.273,78
	Cost				
Commission & Hand Over	Min	Max	Most Likely		63.796,26
- C & HO Team	50000	60000	55000		52.780,14
- Early Defects					11.016,11
Percentage	0,001	0,0045	0,0032		

from preliminary design

		No of units			Description of Unit	Own distribution	Cost per unit			Own distribution
		Min	Max	Most Likely			Min	Max	Most Likely	
Facility Management Cost										
Operation										
Utilities										
Energy										
Estimated as overall	n									
Estimated from breakdown	y									
- treatment		288000	300000	290000			0,1	0,2	0,15	
- pumping		738720	900000	750000			0,1	0,2	0,15	
- Other							10	30	20	
Personnel										
Estimated as overall	n									
Estimated from breakdown	y									
- Engineer		1	2	1			6000	7200	6150	
- Operator		8	12	10			4000	5000	4250	
- Skilled		10	12	10			3200	4300	3500	
- Other		0	0	0			0	0	0	
PPM										
Estimate as overall	y	1	1	1			90000	200000	125000	
Estimate from breakdown	n									
PV of total Life Cycle Replacement										
Use performance model	n									
PV Percentage on capital cost	n									
Annual Percentage on capital cost	y						0,009	0,015	0,011	
Reactive Maintenance										
PV Percentage on capital cost	n									
Annual Percentage on capital cost	y						0,002	0,01	0,005	
Management, overhead and other										
		Min	Max	Most Likely						
Percentage of total PV Maintenance and replacements		0,15	0,2	0,18						

LIFE CYCLE COST PERFORMANCE MODEL - CONCEPT DESIGN STAGE

		Life Cycle Replacement (yrs)			Own distribution	YEAR		
		Min	Max	ML		Frequency of task (yrs)	3	4
Pumps		4	10	6	Lognormal	Input Parameters	7	
Diffusers		5	10	7		Input Parameters	7	
Generators		8	12	10		Input Parameters	10	
Motor Valves		5	12	8		Input Parameters	10	
Services		3	6	5		Input Parameters	5	
External Works		1	10	5		Input Parameters	5	

		No of units			Own distribution	Cost per unit at replacement time			Own distribution	YEAR			
		Min	Max	ML		Min	Max	ML		Frequency of task (yrs)	3	4	
Pumps		8	12	9		4500	7500	5500		7			
Diffusers		4	4	4		7	12500	19000		15000	7		
Generators		1	2	1		10	25000	30000		27000	10		
Motor Valves		10	20	18		10	3000	5000		3800	5		
Services		5	15	12		5	1500	3500		2000	5		
External Works		20	50	35		5	3500	12500		9000	5		
Total											0,00	0,00	
Present Value											0,00	0,00	
Cumulative Present Value											0,00	0,00	


connection with the summary in EPV

LIFE CYCLE COST PERFORMANCE MODEL - CONCEPT DESIGN STAGE


	Expected Present value totals over study period	% of LLC	% of Capital cost
Project Life Cycle Costs	15.638.528		
Capital Cost	5.013.815,05	32,06%	
- Management Costs	460.000,00	2,94%	9,17%
- Overheads	399.646,05	2,56%	7,97%
- Design Costs	131.947,51	0,84%	2,63%
- Construction	3.958.425,23	25,31%	78,95%
- Commission & Hand Over	63.796,26	0,41%	1,27%
Facility Management Cost	10.624.713,37	67,94%	211,91%
- Operation (per year)	5.535.264,22	35,40%	110,40%
- Maintenance	2.975.403,72	19,03%	59,34%
- Life cycle replacement	1.556.442,34	9,95%	31,04%
- Other FM costs (per year)	855.890,40	5,47%	17,07%
Cash flow	6.886.312,02		
Net present value	- 8.752.216,4		

are cashflow's
figures duly
actualised?


Distribution for Project Life Cycle Costs/D9




Summary Information	
Workbook Name	s, ELF Conceptdesign V1-7
Number of Simulations	1
Number of Iterations	10000
Number of Inputs	1009
Number of Outputs	11
Sampling Type	Latin Hypercube
Simulation Start Time	28/04/2004 18.51
Simulation Stop Time	28/04/2004 18.58
Simulation Duration	00.07.00
Random Seed	1736642627



Regression Sensitivity for Project Life Cycle Costs/D9





Summary Statistics			
Statistic	Value	%tile	Value
Minimum	4.689.246,50	5%	4.851.980,00
Maximum	5.373.767,50	10%	4.887.466,00
Mean	5.013.808,76	15%	4.913.232,00
Std Dev	97.842,62	20%	4.931.129,50
Variance	9573178476	25%	4.946.755,00
Skew ness	0,011994858	30%	4.961.785,00
Kurtosis	2,846413615	35%	4.975.227,50
Median	5.013.160,50	40%	4.988.284,00
Mode	4.843.294,00	45%	5.000.813,00
Left X	4.851.980,00	50%	5.013.160,50
Left P	5%	55%	5.025.292,00
Right X	5.175.737,00	60%	5.037.868,00
Right P	95%	65%	5.051.600,50
Diff X	323.757,00	70%	5.065.401,50
Diff P	90%	75%	5.080.369,00
#Errors	0	80%	5.097.214,00
Filter Min		85%	5.117.744,50
Filter Max		90%	5.141.714,00
#Filtered	0	95%	5.175.737,00

LCC3




- Are we authorised to introduce modifications in the process / specs?
- Upon identification of the most important costs, the attention is concentrated at the suitable technical solutions in order to select the most attractive in terms of LCC.



operation	personnel		specs	alternative	Difference
			U	U	
		operators	4	3	
		supervisor	1	1	
					16,67%
	chemicals		Kg/m3	Kg/m3	
		chlorine	1	1	
		lime	2	0	
		calcium	0	2	
					10%
	electricity		Kwh	Kwh	
		well pump	18	19	
		dissolvers	2	0	
		dosing	2	0	
		air blowers	8	0	
		backwash	3	1	
		boosters	30	30	
			63	50	20,63%
maintenance	preventative				
		well pump	yes	yes	
		dosing	yes	no	
		air blowers	yes	no	
		backwash	yes	yes	
		booster	yes	yes	
					19,05%
reactive		well pump	yes	yes	
		dosing	yes	no	
		air blowers	yes	no	
		backwash	yes	yes	
		booster	yes	yes	
				19,05%	

LCC3

- In our case the power from Electricity is the principal cost of operation and pumps are the topic equipment (Consuming more energy).
- We do concentrate therefore on a comparative LCC for different pumps.
- Multi criteria ?
- Deterioration ? 

ELEMENT SELECTION

Booster pump

Click Get Data button to set Element selection

Dataset CISE Demo

CISE Demo

Element Water Installations

15

119

123

5

Sub-Element Booster pump

123

0

Is element accessible in service ? FALSE

Can the element be maintained ? VERO

Can the element be replaced ? VERO

Main Menu

Project ISO

Risk Analysis



Database Values
User Adjustments

Reference Service Life (Years)		
Min	Ave	Max
7	10	15
7	10	15



Risk setting different
Risk setting different
Risk setting different
Risk setting different

Risk setting different

ISO FACTORS				Install Level
	Description	Factor		
A	Quality	1,0	Average	1,73 Max
B	Design	1,1	Good	1,10 Actual
C	Workmanship	1,0	Average	0,51 Min
D	Indoor	1,0	Average	
E	Outdoor	0,9	Harsh	
F	In Use	0,9	Heavy Use	
G	Maintenance	1,1	Some PPM & Full RM	

Set Defaults
Set as Risk

Component ISO Factor 0,98

Expected Service Life (Years)		
Min	Ave	Max
7	10	15



Main Menu
Risk Analysis
Maintenance



0,157143 0,11 0,0733333

Database Values
User Adjustments

Reference Service Life (Years)		
Min	Ave	Max
7	10	15
7	10	15

ISO FACTORS					Install Level
	Description	Factor			
A	Quality	0,9	Poor	1,73	Max
B	Design	0,9	Poor	0,73	Actual
C	Workmanship	0,9	Poor	0,51	Min
D	Indoor	0,9	Harsh		
E	Outdoor	0,9	Harsh		
F	In Use	0,9	Heavy Use		
G	Maintenance	1,2	Full PPM and Full RM		

Set Defaults

Set as Risk

1	0,9	1,2
1	0,9	1,1
1	0,9	1
1	0,9	0,9
0,9	0,9	0,8
0,9	0,9	
1,1	1,2	

Component ISO Factor

0,64

Expected Service Life (Years)		
Min	Ave	Max
4	6	10

0,1825 0,121666667 0,073

the expected service life is re-calculated according to the risk set ISO factor

Main Menu

Risk Analysis

Maintenance



Generic Project Descriptions

Maintenance	
1,2	Full PPM and Full RM
1,1	Some PPM & Full RM
1,0	Some PPM & Some RM
0,9	No PPM and Some RM
0,8	No PPM or No RM

Specific Element Selection

Maintenance	
1,1	Some PPM & Full RM

Specific Element Selection

Element Recovery Maximum		
Min	75	0,75
Ave	85	0,85
Max	95	0,95

Planned Preventative Maintenance

[Click to Select](#)

	Interval Years	Performance Improvement (%)	
PPM1	2	35	35
PPM2	5	30	0
PPM3	0	0	0

Confidence Level
High
Low

Low

Reactive Maintenance

	Interval Condition	Performance Improvement (%)	
RM1	0,5	35	35
RM2	0	0	0



Capital Replacement


	Interval Condition	Performance Improvement (%)
CR	12	100

0,12



- Main Menu
- Element ISO
- Graph





LIFE CYCLE COST

CISE Demo

Booster pump

Discount	3,5													
Discount %	0	1	2	3	4	5	6	7	8	9	10	11	12	
12	PPM1	0	1	1	1	1	1	1	1	1	1	1	1	
6	PPM2	0	0	1	0	1	0	1	0	1	0	1	0	
0	PPM3	0	0	0	0	0	0	0	0	0	0	0	0	
5	RM1	0	0	0	0	0	0	0	1	1	1	1	1	
0	RM2	0	0	0	0	0	0	0	0	0	0	0	0	
1	CR	1	0	0	0	0	0	0	0	0	0	0	0	
	Cost	8.500,00	1.500,00	3.500,00	1.500,00	3.500,00	1.500,00	3.500,00	1.500,00	5.250,00	3.250,00	5.250,00	3.250,00	
	Discounted	8.500,00	1.449,28	3.267,29	1.352,91	3.050,05	1.262,96	2.847,25	1.178,99	3.986,91	2.384,63	3.721,82	2.226,07	

47.250,00
38.702,52

LIFE CYCLE COST

CISE Demo

Booster pump

Discount	3,5													
Discount %	0	1	2	3	4	5	6	7	8	9	10	11	12	
12	PPM1	0	1	1	1	1	1	1	1	1	1	1	1	
6	PPM2	0	0	1	0	1	0	1	0	1	0	1	0	
0	PPM3	0	0	0	0	0	0	0	0	0	0	0	0	
5	RM1	0	1	1	1	1	1	1	1	1	1	1	1	
1	RM2	0	0	0	0	0	0	0	0	0	0	0	0	
1	CR	1	0	0	0	0	0	0	0	0	0	0	0	
	Cost	8.500,00	3.250,00	5.250,00	3.250,00	5.250,00	3.250,00	5.250,00	3.250,00	5.250,00	3.250,00	5.250,00	3.250,00	
	Discounted	8.500,00	3.140,10	4.900,93	2.931,31	4.575,07	2.736,41	4.270,88	2.554,47	3.986,91	2.384,63	3.721,82	2.226,07	

59.500,00
49.402,97

Deterioration Level 1 Data

Expected Service Life (Years)

Min	Ave	Max
7	10	15



Deterioration Level 1 Data

Expected Service Life (Years)

Min	Ave	Max
4	6	10

Deterioration Level 1 Data

Expected Service Life (Years)		
Min	Ave	Max
4	6	10



LIFE CYCLE COST PERFORMANCE MODEL - CONCEPT DESIGN STAGE

		Life Cycle Replacement (yrs)			Own distribution	Input Parameters	YEAR	
		Min	Max	ML			Frequency of task (yrs)	3
Pumps		4	10	6	Lognormal	7	0,00	0,00
Diffusers		5	10	7		7		
Generators		8	12	10		10		
Motor Valves		5	12	8		10		
Services		3	6	5		5		
External Works		1	10	5		5		
	No of units			Own distribution	Cost per unit at replacement time			Own distribution
	Min	Max	ML		Min	Max	ML	
Pumps	8	12	9	Own distribution	4500	7500	5500	Own distribution
Diffusers	4	4	4		12500	19000	15000	
Generators	1	2	1		25000	30000	27000	
Motor Valves	10	20	18		3000	5000	3800	
Services	5	15	12		1500	3500	2000	
External Works	20	50	35		3500	12500	9000	
Total								
Present Value								0,00
Cumulative Present Value								0,00

POWER CALCULATION

$$P = \frac{Q \times H \times G}{366 \times \eta_p \times \eta_m} \quad (\text{KW})$$

P	= power	Kw
Q	= flow rate	m ³ /hr
H	= Head total	m.
η_p	= pump efficiency	n
η_m	= motor efficiency	n
G	= specific gravity	

The basic LCC Equation for pumps



- $LCC = C_{ic} + C_{in} + C_e + C_o + C_m + C_s + C_{env} + C_d$
- C_{ic} initial cost, purchase price
- C_{in} installation and commissioning
- C_e energy cost
- C_o operating cost (labour cost of operat.)
- C_m maintenance cost (parts, manhours)
- C_s down time, loss of production
- C_{env} environmental costs
- C_d decommissioning cost

Life Cycle Cost Calculator

System description and pumps identification

Pouderoyen booster pump station - 66 l/sec.@37 m head

Alternative 1	MM 180-2	HE	86%
Alternative 2	SP 125 2-2	standard	70%

Input: (Insert datas where requested)

- First Investment Cost:	
- Installation and Commissioning:	
- Energy Price €/KWh:	
- Weighted average power KW:	
- Operating Hours (per year):	
Energy Cost Calculated per year	
- Operating Cost (per year):	
- Preventive Maintenance (per year)- (2 inspections /year):	
- Reactive Maintenance (per year) :	
- Other Costs:	
- Down Time Cost (per year):	
- Environmental Cost: (read instructions)*	y y
- Decommissioning / Disposal (-) / (+):	
Life in years:	
Interest rate, %:	
Inflation rate, %:	

Costs in €

	Alt. 1	Alt. 2
8.000,00	6.000,00	
2.600,00	2.500,00	
0,08	0,08	
27,20	34,90	
6.000	6.000	
13.056,00	16.752,00	
1.260,00	1.260,00	
1.760,00	1.660,00	
1.746,00	1.976,00	
-	-	
800,00	600,00	
330,00	330,00	
-	-	
10	10	
6%	6%	
2,7%	2,7%	


Output:

Expected Net Present LCC value	€	166284	194557
of which net present cost for energy :	€	110168	141355
and for preventive maintenance:	€	14851	14007


Energy Cost % :		66,25%	72,65%
preventive maintenance % :		8,93%	7,20%
Net Present O&M total cost % (on investment cost)		1946%	3101%
Pumping Cost per working hour / (m3)	€	0,012	0,014
Average present cost per year	€	16.628,35	19.455,73
Average Cost per month	€	1.385,70	1.621,31




Alternative 1: Annual Life Cycle Costs - Actual and Present Value



Alternative 1: Annual Life Cycle Costs - Actual and Present Value




Alternative 2: Annual Life Cycle Costs - Actual and Present Value



LCC3

- Life span calculation is shorter (10 y) than the one (25-30 y) considered for the utility
- Calculation is more accurate with respect of forecast of inflation and interest rate.
- Environmental costs are directly related to the process / equipment and not general
- How do we insert LCC in the calculator ?
the problem do not exist with the DM.

Share of Cost Elements of Total LCC



LCC summary



Tender specs

Expected Present Value	
3.154,91	
	% of LCC
883,33	28,00%
2.231,57	70,73%
1.361,13	43,14%
331,98	10,52%
191,39	6,07%
347,07	11,00%
-	0,00%
20,00	0,63%
20,00	0,63%

Alternative solution

Expected Present Value	
2.945,82	
	% of LCC
1.100,00	27,96%
1.805,82	70,64%
1.063,85	36,11%
261,06	8,86%
133,83	4,54%
347,07	11,78%
-	0,14%
20,00	0,63%
20,00	0,63%

- WTP
- Investment cost: +19.72%
- LCC: -21.0%
- Pumping station
- Investment cost: +33%
- LCC: - 14%